

New York State Department of Environmental Conservation

Division of Water, Region 3

100 Hillside Avenue Suite 1W White Plains, New York 10603-2860

Phone: (914) 428-2505 • FAX: (914) 428-0323

Website: www.dec.ny.gov



January 6, 2010

Mr. Peter M. Dolan
Supervisor
Town of Tuxedo
One Temple Drive
Tuxedo, NY 10987

Re: Compliance Conference Summary
Town of Tuxedo WWTP
SPDES No.: NY - 0031224

Dear Supervisor Dolan;


Thank you for attending the compliance conference in this office on December 23, 2009 to discuss the poor structural condition of the Town's Wastewater Treatment Plant and the proposed plans to repair, upgrade, or eliminate the facility.

The Department's concerns are the physical age of the plant and the possibility of eminent failure if neglected. As a short term solution, you indicated that the Town has hired a contractor to perform concrete repair work starting this Spring. However, we need to know the long term plans of the Town to either rehabilitate and upgrade the WWTP, or completely eliminate the plant and construct a new larger treatment plant. Considering the condition of the plant and the occasional effluent limit violation, we cannot approve any additional flow to the plant unless substantial improvements are made and a schedule to perform the work is submitted to this office.

Therefore, please submit the Town's decision for long term plans to correct the condition of the WWTP and a proposed schedule of implementation to this office by April 1, 2010.

If you have any questions, please call me at (914) 428-2505 ext. 350. Your cooperation in this matter is appreciated.

Sincerely,

A handwritten signature in black ink that reads "Thomas Rudolph".

Thomas Rudolph, P.E.
Regional Water Engineer